

Measures for Non-Residential Heating & Cooling Efficiency Program			
Item	Size Range	Minimum Qualifying Efficiency	Incentive Per Ton*
Packaged Terminal Air Conditioners			
1	< 7k Btu/h	11.3 EER	\$37
2	≥ 7k and < 15k Btu/h	10.0 EER	\$37
3	≥ 15k Btu/h	9.2 EER	\$37
Packaged Terminal Heat Pumps			
4	< 7k Btu/h	11.3 EER	\$37
5	≥ 7k and < 15k Btu/h	10.0 EER	\$37
6	≥ 15k Btu/h	9.2 EER	\$37
Unitary Air Cooled Air Conditioners			
7	Split Units < 60k Btu/h (5 tons)	12.5 EER or 15.0 SEER	\$45
8	Split Units ≥ 60k and < 132k Btu/h (5-11 tons)	12.0 EER or 13.8 IEER	\$45
9	Split Units ≥ 132k and < 240k Btu/h (11-20 tons)	11.4 EER or 13.0 IEER	\$45
10	Split Units ≥ 240k and < 756k Btu/h (20-63 tons)	10.6 EER or 12.0 IEER	\$45
11	Split Units ≥ 756k Btu/h (63 tons)	10.2 EER or 11.2 IEER	\$45
12	Package Units < 60k Btu/h (5 tons)	12.0 EER or 15.0 SEER	\$45
13	Package Units ≥ 60k and < 132k Btu/h (5-11 tons)	12.0 EER or 13.8 IEER	\$45
14	Package Units ≥ 132k and < 240k Btu/h (11-20 tons)	11.4 EER or 13.0 IEER	\$45
15	Package Units ≥ 240k and < 756k Btu/h (20-63 tons)	10.6 EER or 12.0 IEER	\$45
16	Package Units ≥ 756k Btu/h (63 tons)	10.2 EER or 11.2 IEER	\$45
Unitary Air Cooled Heat Pumps			
17	Split Units < 60k Btu/h (5 tons)	12.5 EER or 15.0 SEER	\$45
18	Split Units ≥ 60k and < 132k Btu/h (5-11 tons)	11.1 EER or 13.5 IEER	\$45
19	Split Units ≥ 132k and < 240k Btu/h (11-20 tons)	10.7 EER or 12.2 IEER	\$45
20	Split Units ≥ 240k and < 756k Btu/h (20-63 tons)	10.1 EER or 11.1 IEER	\$45
21	Package Units < 60k Btu/h (5 tons)	12.0 EER or 15.0 SEER	\$45
22	Package Units ≥ 60k and < 132k Btu/h (5-11 tons)	11.1 EER or 13.5 IEER	\$45
23	Package Units ≥ 132k and < 240k Btu/h (11-20 tons)	10.7 EER or 12.2 IEER	\$45
24	Package Units ≥ 240k and < 756k Btu/h (20-63 tons)	10.1 EER or 11.1 IEER	\$45
Water Cooled Chillers			
25	Rotary / Screw / Scroll Type < 75 tons	0.50 kW/Ton @ IPLV	\$51
26	Rotary / Screw / Scroll Type ≥ 75 and < 150 tons	0.49 kW/Ton @ IPLV	\$53
27	Rotary / Screw / Scroll Type ≥ 150 and < 300 tons	0.44 kW/Ton @ IPLV	\$49
28	Centrifugal < 150 tons	0.44 kW/Ton @ IPLV	\$47
29	Centrifugal ≥ 150 and < 300 tons	0.40 kW/Ton @ IPLV	\$41
30	Magnetic Bearing < 150 tons	0.37 kW/Ton @ IPLV	\$62
31	Magnetic Bearing ≥ 150 and < 300 tons	0.357 kW/Ton @ IPLV	\$52
Air Cooled Chillers			
32	All Sizes	12.5 EER @ IPLV	\$52
Geothermal Heat Pumps			
33	All Sizes	18.1 EER	\$42
Variable Frequency Drives			
34	Fan Motors		\$56 per hp
35	Hot Water Pump Motor		\$56 per hp

*For more information, please call 1-888-366-8280. The program is available until fully subscribed. Rebate incentive cannot exceed 75% of the total invoice amount. Rebate amounts are subject to modifications without notice, and projects must be complete before rebates will be paid. Minimum Qualifying Efficiency Level for Water Cooled Chillers and Air Cooled Chillers represents the Partial Load Efficiency (IPLV).

Item	Size Range	Minimum Qualifying Efficiency	Incentive Per Ton*
36	Chilled/Condenser Water Pump Motor		\$56 per hp
HVAC Economizers			
37	On Air Handler < 10 tons		\$98 per unit
38	On Air Handler ≥ 10 tons		\$156 per unit
39	On Package Unit < 10 tons		\$98 per unit
40	On Package Unit ≥ 10 tons		\$156 per unit
Mini Split Air Conditioners			
41	Ductless Level 1 ≤ 60k Btu/h	11.8-13.7 EER or 14.0-18.0 SEER	\$60
42	Ductless Level 2 ≤ 60k Btu/h	13.8-15.9 EER or 18.1-21.9 SEER	\$110
43	Ductless Level 3 ≤ 60k Btu/h	16.0 EER or 22.0 SEER	\$150
44	Ducted Level 1 ≤ 60k Btu/h	11.8-13.7 EER or 14.0-18.0 SEER	\$60
45	Ducted Level 2 ≤ 60k Btu/h	13.8-15.9 EER or 18.1-21.9 SEER	\$110
46	Ducted Level 3 ≤ 60k Btu/h	16.0 EER or 22.0 SEER	\$150
Mini Split Heat Pumps			
47	Ductless Level 1 ≤ 60k Btu/h	11.8-13.7 EER or 14.0-18.0 SEER	\$60
48	Ductless Level 2 ≤ 60k Btu/h	13.8-15.9 EER or 18.1-21.9 SEER	\$110
49	Ductless Level 3 ≤ 60k Btu/h	16.0 EER or 22.0 SEER	\$150
50	Ducted Level 1 ≤ 60k Btu/h	11.8-13.7 EER or 14.0-18.0 SEER	\$60
51	Ducted Level 2 ≤ 60k Btu/h	13.8-15.9 EER or 18.1-21.9 SEER	\$110
52	Ducted Level 3 ≤ 60k Btu/h	16.0 EER or 22.0 SEER	\$150
Variable Refrigerant Flows			
53	≥ 60k and < 132k Btu/h	14.0 EER or 14.2 IEER	\$80
54	≥ 132k and < 240k Btu/h	13.0 EER or 13.7 IEER	\$70
55	≥ 240k Btu/h	12.4 EER or 13.0 IEER	\$60
Water Source Air Conditioners			
56	≤ 132k Btu/h	14.0 EER	\$80
Water Source Heat Pumps			
57	≤ 132k Btu/h	14.0 EER	\$80

*For more information, please call 1-888-366-8280. The program is available until fully subscribed. Rebate incentive cannot exceed 75% of the total invoice amount. Rebate amounts are subject to modifications without notice, and projects must be complete before rebates will be paid. Minimum Qualifying Efficiency Level for Water Cooled Chillers and Air Cooled Chillers represents the Partial Load Efficiency (IPLV).